



FORM 196  
Rev. 04/03

### COUNTY OF LOS ANGELES FIRE DEPARTMENT FIRE PREVENTION DIVISION

Fire Prevention Engineering  
5823 Rickenbacker Road  
Commerce, CA 90040  
Telephone (323) 890-4125 Fax (323) 890-4129

### Information on Fire Flow Availability for Building Permit

#### For All Buildings Other Than Single Family Dwellings (R-3)

#### INSTRUCTIONS:

Complete parts I, II (A) when:

Verifying fire flow, fire hydrant location and fire hydrant size.

Complete parts I, II (A), & II (B) when:

For buildings equipped with fire sprinkler systems, and/or private on-site fire hydrants.

#### PROJECT INFORMATION (To Be Completed By Applicant)

#### PART I

Building Address: [REDACTED]

City or Area: Inglewood

Nearest Cross Street: [REDACTED]

Distance of Nearest Cross Street: 200 ft

Applicant: [REDACTED] Telephone: (310) [REDACTED]

Address: [REDACTED]

City: Inglewood

Occupancy (Use of Building): Restaurant Sprinklered: Yes  No

Type of Construction: Type - 5

Square Footage: 6365 Number of Stories: 2

Present Zoning: Commercial

[Signature]  
Applicant's Signature

3/2/18  
Date

PART II-A

INFORMATION ON FIRE FLOW AVAILABILITY  
(To be completed by Water Purveyor)

Location 4110 W Century Blvd

Distance from Nearest Property Line ~245 ft. Hydrant Number 3858  
Size of Hydrant 6" Size of Water main 8" DI

Static PSI 64 Residual PSI 53 Orifice size 4" Pitot 38

Fire Flow at 20 PSI 5903 GPM Duration 2 Hours Flow Test Date / Time 03/07/18 @ 6:21 pm

Location \_\_\_\_\_

Distance from Nearest Property Line \_\_\_\_\_ Hydrant Number \_\_\_\_\_  
Size of Hydrant \_\_\_\_\_ Size of Water main \_\_\_\_\_

Static PSI \_\_\_\_\_ Residual PSI \_\_\_\_\_ Orifice size \_\_\_\_\_ Pitot \_\_\_\_\_

Fire Flow at 20 PSI \_\_\_\_\_ Duration \_\_\_\_\_ Flow Test Date / Time \_\_\_\_\_

Location \_\_\_\_\_

Distance from Nearest Property Line \_\_\_\_\_ Hydrant Number \_\_\_\_\_  
Size of Hydrant \_\_\_\_\_ Size of Water main \_\_\_\_\_

Static PSI \_\_\_\_\_ Residual PSI \_\_\_\_\_ Orifice size \_\_\_\_\_ Pitot \_\_\_\_\_

Fire Flow at 20 PSI \_\_\_\_\_ Duration \_\_\_\_\_ Flow Test Date / Time \_\_\_\_\_

PART II-B SPRINKLERED BUILDINGS/PRIVATE FIRE HYDRANTS ONLY

Detector Location (check one)  Above Grade  Below Grade  Either

Backflow Protection Required (Fire Sprinklers/Private Hydrant) (check one)  Yes  No

Minimum Type of Protection Required (check one)  Single Check Detector Assembly

Double Check Detector Assembly  Reduced Pressure Principle Detector Assembly

Golden State Water Company  
Water Purveyor

[Signature]  
Signature

3/9/2018  
Date

Operations Engineer  
Title

**This Information is Considered Valid for Twelve Months**

Fire Department approval of building plans shall be required prior to the issuance of a Building Permit by the jurisdictional Building Department. Any deficiencies in water systems will need to be resolved by the Fire Prevention Division only prior to this department's approval of building plans.

PROJECT ADDRESS: 4110 W Century Blvd